



Programme implemented by:



QUESTIONS AND ANSWERS

Questions and answers apply to request for clarifications in regard to ITB for Rehabilitation and adaptation of the Grammar School building in Svilajnac, UNOPS-SFRS-2015-W-037.

1. **Q:** Could you please define what is meant under term “hard sandwiched terwool”?

A: Characteristics of hard sandwiched terwool described in Weatherproofind, Section 7.1 are as follows: coefficient of thermal conductivity $\lambda=0,038$ W/mK, hardness 0,0027 N/mm².

2. **P:** Možete li pojasniti šta se podrazumeva pod pojmom “tvrđi tervol”?

O: Karakteristike tvrdog tervola opisanog u Izolaterskim radovima, pod delom 7.1 su sledeće: koeficijent toplotne provodljivosti $\lambda=0,038$ W/mK, tvrdoća 0,0027 N/mm².

Belgrade, 09 June 2015