



Republic of Serbia



Programme Funded by EU



Schweizerische Eidgenossenschaft  
Confédération suisse  
Confederazione Svizzera  
Confederaziun svizra

Swiss Agency for Development  
and Cooperation SDC



Implementing Partner

EUROPEAN  
PROGRES

## Questions and Answers

### Provision of reconstruction works on floors in the Primary School “Stojan Novakovic” in Blace ITB UNOPS-EP-2017-W-025

I

Q: Which is the thickness of the existing cement screed which needs to be repaired (position no. 2)?

**A: The thickness of the existing cement screed is 4.5cm**

II

Q: Should supporting documents (financial reports, balance sheets, registry documents, tax administration receipts, contracts, etc...) be translated into English language?

**A: There is no need to translate the supporting documents into English language.**